



431 River Road  
Bow, NH 03304

July 11, 2019

Submitted on-line via NetDMR

U.S. Environmental Protection Agency  
Water Technical Unit (SMR-04)  
OES4 – SMR  
5 Post Office Square - Suite 100  
Boston, MA 02109-3912

Reference: NPDES Permit No. NH0001465, Merrimack Station, GSP Merrimack LLC,  
issued June 25, 1992, modified October 22, 1992, modified January 10, 2018.

Dear Sir/Madam:

Merrimack Station  
Monthly NPDES Discharge Monitoring Report  
June 2019

In compliance with Part I, Section B.1., of the NPDES permit (see Reference), Granite Shore Power LLC (GSP) herein submits the monthly NPDES report for Merrimack Station for the month of June. With the exception of Outfall 003A, all sampling and analyses were conducted by station personnel in accordance with EPA approved procedures referenced at 40 CFR Part 136. Eastern Analytical, Inc. of Concord, NH, performed the total suspended solids and oil and grease analyses on the monthly grab samples collected at Outfall 003A. There were no oily sheens, floating solids, or foam observed in any of the outfall discharges in other than trace amounts. There were no permit noncompliances recorded during the month.

As instructed by the agencies, GSP now reports a concentration of zero ("0") when the analytical result is less than the method detection limit (MDL). For this report, the following MDLs were used: Total Residual Oxidants = 0.01 mg/l (SM 4500-Cl D – 2011); Total Residual Oxidants = 0.05 mg/l (SM 4500-Cl E – 2011); Oil & Grease = 5.0 mg/l (EPA 1664B); Total Suspended Solids = 5.0 mg/l (SM 2540D – 2011).

The pH at Outfall 003 (Station S-0) dipped below 6.5 SU on a handful of days during the month. Compliance was maintained with the permit however, as the effluent pH closely tracked the naturally occurring river pH at Station N-5 (see the attached data sheets), and any discrepancies were within the analytical limits of the equipment accuracy and precision. As such, these low pH values were not the result of activities at Merrimack Station and so should not be recorded as violations in the Integrated Compliance Information System, Enforcement and Compliance History Online, or any other EPA compliance database.

July 11, 2019

This report is required by, and prepared specifically for, the U.S. Environmental Protection Agency (EPA). It presents truly, accurately and completely, the observed measurements and analyses required by the EPA to be performed or submitted, but only such observed results. It is not intended as an assertion of the accuracy of any instrument, reading, or analytical result, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions regarding this report, please call Allan Palmer, Senior Engineer, at (603) 230-7951.

Sincerely,

GRANITE SHORE POWER



---

Elizabeth H. Tillotson

Executive Director of Administration & Regulatory Affairs

Enclosures

PUBLIC SERVICE OF NEW HAMPSHIRE  
MERRIMACK GENERATING STATION  
ENVIRONMENTAL MONITORING PROGRAM

MONTHLY SUMMARY REPORT FOR June 2019

STATION: N5

PARAMETER: PH

DAY	MAXIMUM (PARAM)	TIME	DAILY AVERAGE	MINIMUM (PARAM)	TIME	#of INT.
06/01/19	6.80	0130	6.78	6.75	2330	96
06/02/19	6.79	1630	6.75	6.73	0000	96
06/03/19	6.76	2130	6.74	6.72	0315	96
06/04/19	6.84	1315	6.76	6.72	0945	96
06/05/19	7.11	1000	6.76	6.74	0215	96
06/06/19	6.81	0400	6.75	6.73	1930	96
06/07/19	6.81	1400	6.79	6.75	0015	96
06/08/19	6.80	1100	6.78	6.75	2300	96
06/09/19	6.75	0015	6.71	6.67	2345	96
06/10/19	6.68	0030	6.65	6.63	2230	96
06/11/19	6.69	2200	6.64	6.62	1200	96
06/12/19	6.75	1930	6.72	6.68	0030	96
06/13/19	6.78	1500	6.75	6.73	0745	96
06/14/19	6.74	0015	6.72	6.69	0845	96
06/15/19	6.82	1615	6.78	6.73	0015	96
06/16/19	6.79	0045	6.74	6.71	2115	96
06/17/19	6.74	1530	6.72	6.70	0945	96
06/18/19	6.77	1630	6.74	6.72	0100	96
06/19/19	6.79	1645	6.76	6.74	1115	96
06/20/19	6.77	1715	6.74	6.72	1000	96
06/21/19	6.82	1730	6.77	6.74	0415	96
06/22/19	6.84	0800	6.82	6.79	0000	96
06/23/19	6.81	0730	6.79	6.77	2345	96
06/24/19	6.78	0015	6.75	6.70	1930	96
06/25/19	6.73	0815	6.69	6.66	2130	96
06/26/19	6.69	1015	6.66	6.63	1230	96
06/27/19	6.73	1400	6.70	6.68	0030	96
06/28/19	6.77	1545	6.73	6.70	0030	92
06/29/19	6.76	1715	6.72	6.69	0830	96
06/30/19	6.74	1900	6.72	6.68	1100	96
<hr/>						
AVERAGE	6.78		6.74	6.71		
STD DEV.:	0.07		0.04	0.04		

PUBLIC SERVICE OF NEW HAMPSHIRE  
MERRIMACK GENERATING STATION  
ENVIRONMENTAL MONITORING PROGRAM  
MONTHLY SUMMARY REPORT FOR June 2019

STATION: Zero

PARAMETER: PH

DAY	MAXIMUM (PARAM)	TIME	DAILY AVERAGE	MINIMUM (PARAM)	TIME	#of INT.
06/01/19	6.59	1900	6.53	6.37	2000	96
06/02/19	6.60	1830	6.50	6.42	1415	96
06/03/19	6.58	1345	6.53	6.49	0630	96
06/04/19	6.63	1300	6.52	6.43	0945	96
06/05/19	7.16	0930	6.50	6.46	0645	96
06/06/19	6.63	1715	6.56	6.46	0015	96
06/07/19	6.61	1530	6.57	6.53	1345	96
06/08/19	6.62	1815	6.58	6.51	0815	96
06/09/19	6.60	1815	6.54	6.45	1600	96
06/10/19	6.65	2300	6.49	6.45	2015	96
06/11/19	6.60	2245	6.50	6.44	1030	96
06/12/19	6.56	2300	6.52	6.46	1330	96
06/13/19	6.54	0015	6.51	6.46	0000	96
06/14/19	6.55	1715	6.49	6.44	0730	96
06/15/19	6.65	2130	6.56	6.50	0930	96
06/16/19	6.67	1745	6.57	6.51	0445	96
06/17/19	6.61	1315	6.54	6.51	1900	96
06/18/19	6.60	2000	6.55	6.51	1315	96
06/19/19	6.77	2115	6.55	6.50	0545	96
06/20/19	6.61	1700	6.51	6.44	0500	96
06/21/19	6.58	1400	6.53	6.49	0515	96
06/22/19	6.72	1045	6.62	6.53	0600	96
06/23/19	6.80	0000	6.62	6.48	0730	96
06/24/19	6.97	0815	6.79	6.58	1900	96
06/25/19	6.93	0200	6.68	6.49	0000	96
06/26/19	6.99	0000	6.65	6.45	0315	96
06/27/19	7.06	1515	6.99	6.92	2300	96
06/28/19	6.93	0015	6.75	6.62	0815	92
06/29/19	6.72	1645	6.66	6.60	0330	96
06/30/19	6.77	1630	6.69	6.61	0145	96
AVERAGE	6.71		6.59	6.50		
STD DEV.:	0.17		0.11	0.10		